

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

CERTIFICATE

No. B 098200 0030 Rev. 00

Holder of Certificate: **Caledonian Cables Limited**
 1/F., CMA Building, 64-66 Connaught Road Central,
 Central and Western District
 HONG KONG

Certification Mark:



Product: **Flame retardant cables**
(XLPE insulated LSZH sheathed Armoured cables)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 64100180526601
Valid until: 2023-09-05

Date, 2018-09-06 (Boris Ouyang)



A4 / 07.17



Product Service

CERTIFICATE

No. B 098200 0030 Rev. 00

Model(s): FTX300 1RZ1MAZ1-R (N2XRH),
FTX400 1RZ1MZ1-R (N2XRH)

Parameters:

| | |
|----------------------------|--|
| Rated voltage: | 600/1000V |
| Conductors: | Plain or tinned copper wires |
| Insulation: | XLPE, GP8 |
| Bedding: | LSZH |
| Armour: | |
| FTX300 1RZ1MAZ1-R (N2XRH): | armoured with aluminium wire |
| FTX400 1RZ1MZ1-R (N2XRH): | armoured with galvanized steel wire |
| Sheath: | LSZH, LTS 1 |
| Sizes: | |
| FTX300 1RZ1MAZ1-R (N2XRH): | 1C x 50mm ² to 1C x 1000mm ² |
| FTX400 1RZ1MZ1-R (N2XRH): | 2C x 1.5mm ² to 4C x 400mm ² , 5C x 1.5mm ² to 5C x 70mm ² , 7C x 1.5mm ² to 37C x 4mm ² |

Tested according to: BS 6724:2016

Production Facility(ies): 096882

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT