



Ref. Certif. No.

HU-002917

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

### CB TEST CERTIFICATE

Product

Non-sheathed cables for fixed wiring

Name and address of the applicant

Caledonian Cables Limited  
1/F., CMA Building, 64-66 Connaught Road Central,  
Hong Kong

Name and address of the manufacturer

Caledonian (Shandong) Cables Limited  
Northeast Plant, Inside of Dianliu Industrial Park,  
Shizi Park, DongJia Town, Licheng, 250100 Jinan,  
P. R. CHINA

Name and address of the factory

See on page 2

Note: *When more than one factory, please report on page 2*

Ratings and principal characteristics

450/750V

Trademark / Brand (if any)

Caledonian Cables Limited

Customer's Testing Facility (CTF) Stage used

---

Model / Type Ref.

60227 IEC 01 1X1,5...10mm<sup>2</sup> 450/750V,  
60227 IEC 01 1X1,5...400mm<sup>2</sup> 450/750V

Additional information (if necessary may also be reported on page 2)

---

A sample of the product was tested and found to be in conformity with

IEC 60227-3:1993 + AMD1:1997  
IEC 60227-1:2007  
IEC 60227-2:1997 + AMD1:2003

As shown in the Test Report Ref. No. which forms part of this Certificate

GL1903938

This CB Test Certificate is issued by the National Certification Body

 **TÜVRheinland**®

Date: 2020-05-27

TÜV Rheinland InterCert Kft., Division MEEI  
H-1132 Budapest, Váci út 48/A-B  
[www.tuv.com](http://www.tuv.com)



Signature:

Gabor Kassai