

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50471427

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
K.K

Unser Zeichen *Our Reference*
01-Renviv-60377190 001

Ausstellungsdatum *Date of Issue*
23.12.2020 (day/mo/yr)

Genehmigungsinhaber *License Holder*
Caledonian Cables Limited
1/F., CMA Building,
64-66 Connaught Road Central
Hong Kong

Fertigungsstätte *Manufacturing Plant*
Caledonian (Shandong) Cables Limited
Jiyang Branch
No. 17 Yellow River Street,
Jibei Develop Zone,
Jiyang District, Jinan,
251400 Shandong
P.R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
IEC 60502-1:2004+A1

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Cable (0.6/1kV Power Cable)

Type Designation :

12

N2XY (FGD300 1RV-R) CU/XLPE/PVC 1X1,5...800mm²
NA2XY (FGD300 1ARV-R) AL/XLPE/PVC 1X10...800mm²
NA2XY (FGD400 1ARV-R) AL/XLPE/PVC 2...5X10...400mm²
7...48x1,5...2,5mm²
N2XY (FGD400 1RV-R) CU/XLPE/PVC 2...5X1,5...400mm²

Rating Voltage (Uo/U) : 0.6/1kV

Max. conductor temperature: 90°C

Mark of Origin (Trademark): Caledonian Cables Limited

Remark: Refer to test report 60377190 001 for details.

Continued on page 0002

12

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

